

Solution Problem Set Sizing

Fall 2000.

Problem 1 Reactor SizingFrom HYSYS Reactor Volume = 50 ft³.Heuristic Rules (Rule 4, Table 9.6)
Optimum L/D = 3.

$$\therefore \frac{\pi D^2}{4} \cdot L = 50, L = 3D$$

Solving

$H = 8.1 \text{ ft}$	$= \frac{2.45 \text{ m}}{0.818 \text{ m}}$
$D = 2.7 \text{ ft}$	$= 0.818 \text{ m}$

$$\text{Cross. Area} = \frac{\pi D^2}{4} = 3.69 \text{ ft}^2$$

Agit Rule

This is a gas/liquid separator as well
 Rule 2, Table 9.6 says gas/lig separators
 are usually vertical.

Check for entrainment:

$$u = k \sqrt{\rho_e / \rho_v - 1} \text{ ft/sec}, k = 0.35$$

without demister to prevent entrainment

(Rule 9, Table 9.6).

From HYSYS, $\rho_e = \frac{54}{45.4} \text{ lb/ft}^3$, $\rho_v = \frac{0.1}{0.1} \text{ lb/ft}^3$

$$\therefore u_{\max} = 0.35 \sqrt{\frac{45.4}{54} - 1} = 8.1 \text{ ft/sec.}$$

Actual $u = \frac{\text{gas flow}}{\text{area}} = \frac{23.81 \text{ lb/hr}}{3.69 \text{ ft}^2 \times 1088 \text{ lb/ft}^3} = \frac{59.3 \text{ ft}}{\text{hr}} = 0.1 \text{ ft/sec}$

No problem with entrainment

(2)

1. Part b.

Rule 4, Table 9.17

$$\text{Power required} = 1.5 \text{ hp}/1000 \text{ gal.}$$

$$\text{Actual volume} = 50 \text{ ft}^3 \approx 400 \text{ gal}$$

$$\therefore \text{hp for agitator} = \frac{1.5 \text{ hp}}{1000 \text{ gal}} \times 400 \text{ gal}$$

$$= \underline{\underline{0.60 \text{ hp}}}$$

$$= \underline{\underline{0.45 \text{ kW}}}$$

$$\text{Cost of utility} = \$0.06/\text{kW-hr} \text{ (Table 6, Chapter 3)}$$

$$\begin{aligned} \text{Cost} &= 0.45 \text{ kW} \times 340 \frac{\text{days} \times 24 \frac{\text{hr}}{\text{day}}}{\text{yr}} \\ &\quad \times 0.06/\text{kW-hr} \\ &= \underline{\underline{\$213.8 / \text{yr}}} \end{aligned}$$

c.. Heating utility. Temp of Reactor is 200°F

Use LP steam (lowest cost) at $\underline{\underline{320^\circ\text{F}}}$

$$\Delta T = 320 - 200 = 120^\circ\text{F} \text{ (constant)}$$

$$U = 2000 \frac{\text{Btu}}{\text{hr ft}^2 \text{ F}} \text{ (Rule 8, Table 9.11)} \\ \text{(for reboiler)}$$

$$\text{Area} = \frac{Q}{U A F \Delta T} =$$

$$Q = 3.128 \times 10^5 \text{ Btu/hr from HYSYS}$$

(3)

Assume $P \approx 1$

$$\text{Area} = \frac{3.128 \times 10^5 \text{ Btu/hr}}{200 \frac{\text{Btu}}{\text{hr ft}^2 \text{ F}} \times 120^\circ \text{ F} \times 1}$$

$$= 13.03 \text{ ft}^2 = 1.19 \text{ m}^2$$

use a heating coil.

$$\text{Cost of Area} = 3.128 \times 10^5 \frac{\text{Btu}}{\text{hr}} \times$$

$$\frac{1054 \text{ J}}{\text{Btu}} \times 10^{-9} \frac{\text{GJ}}{\text{J}}$$

$$\times 8160 \frac{\text{hr}}{\text{yr}} \times \frac{\$3.17}{\text{GJ}}$$

$$= \$ \underline{\underline{8360. / \text{yr}}}$$

P.

Problem 2

a.

a. Column Diameter.

Estimated Vapor Velocity = 6 ft/sec
for vac. column

Rule 2, Table 9.14.

Max vapor flow = 4402 lb/hr (to condenser)

Vapor density = 0.0405 lb/ft³.

$$\text{Volumetric gas flow} = \frac{4402}{0.0405} \approx \cancel{10,000}$$

$$\approx 11000 \text{ ft}^3/\text{hr}$$

$$= 30.56 \text{ ft}^3/\text{sec}$$

$$\text{Area} = \frac{30.56 \text{ ft}^3/\text{sec}}{6 \text{ ft/sec}} = 5.09 \text{ ft}^2$$

$$\text{Diameter} = \underline{\underline{2.54}} \text{ ft}$$

b. Column Height

No of stages = 33.

Traffic Efficiency = 60-90% for hydrocarbon
~~rule~~ Rule 4, 9.14

User Eff = 75%.

$$\text{No of trays} = \frac{33}{.75} = 44.$$

(5)

Additional area at top = 4 ft ~~at top~~. Rule 13
 bottom = 6 ft " "

Total height

Tray spacing = ~~4~~ 2 ft for Rule 1, 9.14

$$\begin{aligned} \text{Total Height} &= 24 \times 2 + 6 + 4 \\ &= \underline{\underline{98}} \text{ ft} = \underline{\underline{29.6 \text{ m}}} \end{aligned}$$

(c) Reboiler

Duty = 6.22×10^5 Btu/hr from HYSYS

Trip = 240°F

Use LP steam at 320°F

$$\Delta T = 320 - 240 = 80^\circ\text{F}$$

$$U = 200 \frac{\text{Btu}}{\text{hr ft}^2 \text{ of }} , (\text{Rule 8, 9.11})$$

$$A = \frac{Q}{U(\Delta T)} = \underline{\underline{38.87 \text{ ft}^2}}$$

Size & cost as a double-pipe heat exchanger since area is so small

$$\begin{aligned} \text{Cost of steam} &\rightarrow 6.22 \times 10^5 \frac{\text{Btu}}{\text{hr}} \times 8160 \frac{\text{hr}}{\text{yr}} \times \frac{1054 \times 10^9 \text{ GJ}}{\text{Btu}} \\ &\times \$3.17/\text{GJ} = \underline{\underline{\$16,625 / \text{yr}}} \end{aligned}$$

d. Condenser

$$\text{Duty} = 8.415 \times 10^5 \text{ Btu/hr}$$

$$\text{Temp} = 214^\circ\text{F}$$

Use Cooling Water in at 90°F , out at 115°F
(Rule 2, 9.11)

$$\Delta T_1 = 214 - 90 = 120^\circ\text{F}$$

$$\Delta T_2 = 214 - 115 = 100^\circ\text{F}$$

$$(\Delta T)_{lm} = 111^\circ\text{F}.$$

$$A = Q / u \Delta T = 50.5 \text{ ft}^2$$

$$\begin{aligned} \text{Cooling water Cost} &= \$ \frac{16}{GJ} \times 8.415 \times 10^5 \frac{\text{Btu}}{\text{hr}} \\ &\quad \times 8160 \frac{\text{hr}}{\text{yr}} \times \frac{1054 \times 10^{-3}}{\text{J}} \\ &= \underline{\underline{\$1135/\text{yr}}} \end{aligned}$$

7

c. Accumulator Drum

Assume holdup = 5 min
 (Rule 5, 9.6)

$(L/D)_{opt} = 3$ (Rule 4, 9.6)

liquid flow = ~~reflux~~ Reflux flow +
 distillate flow
 = 4402 lbs/hr

density = 54 lb/ft³

$$\therefore \text{flow} = 81.5 \text{ ft}^3/\text{hr}$$

$$= 1.358 \text{ ft}^3/\text{min}$$

$$\text{Volume} = 5 \text{ min} \times \text{liq flow}$$

$$= 5 \text{ min} \times 1.358 \text{ ft}^3/\text{min}$$

$$= 13.5 \text{ ft}^3$$

$$= \frac{\pi D^2}{4} \cdot H = \frac{\pi D^2}{4} \cdot (3D)$$

$$\therefore D = 1.79 \text{ ft} \approx \underline{\underline{2 \text{ ft}}}$$

$$H = \underline{\underline{6 \text{ ft}}}$$

(8)

F. Reflex Pump

$$\Delta P = \rho gh / g_c$$

neglecting frictional losses, kinetic losses

h = Height of column.

pump is at base of column, must pump to top of column.

$$\rho = 54 \text{ lb/ft}^3 \text{ from HYSX}$$

Reflex flow = 8.141 gpm (from HYSX)

$$\begin{aligned} \Delta P &= 54 \frac{\text{lb}}{\text{ft}^2} \times \frac{32.2 \text{ ft/sec}^2 \times 98 \text{ ft}}{32.2 \frac{\text{lbm} \cdot \text{ft}}{\text{sec}^2}} \\ &= 5292 \frac{\text{lbft}}{\text{ft}^2} = 36.75 \frac{\text{lbft}}{\text{in}^2} (\text{psi}) \end{aligned}$$

$$\text{Power} = \frac{\text{flow (gpm)} \cdot \Delta P (\text{psi})}{(1714)(\epsilon)}$$

(Rule 1, 9.9)

$\epsilon = 45\%$ (Rule 4, 9.9)

$$\begin{aligned} \therefore \text{Power} &= \frac{(8.141 \text{ gpm})(36.75 \text{ psi})}{(1714)(0.45)} \\ &= 0.38 \text{ hp} = 0.25 \text{ kW} \end{aligned}$$

(9)

NPSH = Net Pos. Suction Head

$$= 4-20 \text{ ft of liquid} \quad (\text{Reqs } 2, 9.9)$$

Use 10 ft of liquid.

\therefore Place accumulator 10 ft above ground.

~~+ 5 ft~~

Pressure at top of column = 3 psi

Pressure at inlet of pump = 3 + 10 ft of liquid

This must be greater than vapor pressure of liquid to prevent cavitation

$$\begin{aligned} \text{Pressure at pump exit} &= 3 \text{ psi} + \frac{10 \text{ ft sec}}{\text{ft sec}} \\ &+ 36.75 \text{ psi} \end{aligned}$$

$$\approx \underline{40 \text{ psi}}$$

Pipe size for ~~vapor~~ liquid line

\therefore Use $(S + D/3) \approx 5 \text{ ft/sec}$ for liquid discharge line

$$\begin{aligned} \text{Liq. flow} &= 8.141 \text{ gpm} = 1.08 \text{ ft}^3/\text{sec} \\ &\times \frac{35.605}{60} \text{ ft/sec} \end{aligned}$$

$$\begin{aligned} \text{Area} &= \frac{1.08 \text{ ft}^3/\text{sec}}{5 \text{ ft/sec}} = .0036 \text{ ft}^2 \\ &= .522 \text{ in}^2 \end{aligned}$$

$$\pi D^2/4 = .522 \quad \boxed{D = .81 \text{ in}}$$

Pipe size for vapor flow

Vapor velocity = 200 ft/sec.

$$\text{Vapor Flow} = \text{Reflux} + \text{Distillate}$$

$$= 30.56 \text{ ft}^3/\text{sec}$$

$$\therefore A_{ka} = \frac{30.56 \text{ ft}^3/\text{sec}}{200 \text{ ft/sec}} = 0.1528 \text{ ft}^2 \\ = 22 \text{ } \cancel{\text{ft}} \text{ in}^2$$

$$= \pi D^2/4 \therefore D = 5.28 \text{ } \cancel{\text{ft}} \text{ in}$$

~~Yes, vapor line~~

No, do not insulate vapor line. Reduce cooling duty for condenser.

Annual pumping cost?

$$= 0.25 \text{ kw} \times 8760 \frac{\text{hr}}{\text{yr}} \times \$0.06/\text{kwhr} \\ = \underline{\underline{\$138/\text{yr}}}$$